



REQUIRED MINIMUM CASING

CARRIER PIPE	CASING SIZE	CASING WALL	NUMBER INSULATOR SKIDS	BAND WIDTH
2"	8"	0.375	4@90°	8"
4"	10"	0.375	4@90°	8"
6"	12"	0.375	4@90°	8"
8"	16"	0.375	4@90°	8"
10"	20"	0.375	4@90°	8"
12"	24"	0.375	4@90°	8"
16"	30"	0.500	2 ON TOP 4 ON BOTTOM	12"

1. INSULATORS TO BE ADVANCED PRODUCTS MODEL SSIM STAINLESS STEEL CENTERED AND RESTRAINED. SPACED AS SHOWN
2. CASING END SEALS TO BE ADVANCED PRODUCTS MODEL AC
3. CASING REQUIRED FOR STATE HIGHWAY CROSSINGS, UNDER SANITARY SEWERS, UNDER LARGE DIAMETER OR MULTI-BARRELL STORM PIPES, UNDER RAILROAD OR OTHER JOB SPECIFIC SURFACE OBSTRUCTIONS.
4. CASINGS SHALL EXTEND A MINIMUM OF TWO (2) FEET PAST THE EDGE OF PAVEMENT OR OTHER OBSTRUCTION, EXTEND TEN (10) FEET PAST A SEWER UNDER CROSSING, OR SUCH ADDITIONAL DISTANCE AS REQUIRED BY THE HIGHWAY DEPARTMENT OR RAILROAD.

Jefferson Utilities Inc.

270 Industrial Boulevard
Kearneysville, WV 25430

**CASING INSTALLATION,
OPEN CUT OR
BORE AND JACK**

Not to Scale

W-4.00

REVISED:
AUGUST 5, 2013